



TOWN OF NEWBURGH
WATER AND SEWER DEPARTMENT
308 GARDNERTOWN ROAD
NEWBURGH, NY 12550

PHONE: 845-564-7813

FAX: 845-566-8903

Notice of Violation

Violation ID 2026 78831
Newburgh Consolidated WD
Federal ID NY3503578

July 14, 2026

A Notice of Violation was issued to the Town of Newburgh on July 7, 2026 for failure to notify Orange County Department of Health within 24 hours of a water service interruption in accordance with Section 5-1.23 of the NYS Sanitary Code.

On July 4, 2026, a watermain break occurred at 38 North Plank Road, affecting Helen Terrace, Winding Lane and North Plank Business Section. OCDOH was not notified of this work until July 7, 2026, exceeding the 24-hour notification rule, resulting in this violation.

Precautionary boil water notices were hand delivered and posted on the Town website at the time of the event. Total coliform samples were collected for 2 consecutive days. Following negative sample results, the boil water advisory was lifted.

There were no negative health effects or populations at risk as a result of this violation.

There were no alternate water sources used during this time.

The Town has implemented additional protocols to ensure that all notifications, including those after normal business hours and holidays be made in a timely manner in accordance with County and State requirements.

For more information regarding this notification please contact the Town of Newburgh Water Department at (845) 564-7813.