

RICHARD D. MCGOEY, P.E. (NY & PA) WILLIAM J. HAUSER, P.E. (NY, NJ & PA) MARK J. EDSALL, P.E. (NY, NJ & PA) JAMES M. FARR, P.E. (NY & PA)

MAIN OFFICE 33 Airport Center Drive Suite 202 New Windsor, New York 12553

(845) 567-3100 fax: (845) 567-3232 e-mail: mheny@mhepc.com

## TOWN OF NEWBURGH **PLANNING BOARD REVIEW COMMENTS**

**PROJECT: PROJECT NO.: PROJECT LOCATION:** PROJECT REPRESENTATIVE: ESPOSITO ASSOCIATES **REVIEW DATE:** MEETING DATE:

**RIVERA CLEARING & GRADING** 11-29 SECTION 6, BLOCK 1, LOT 2.14 **30 SEPTEMBER 2013 3 OCTOBER 2013** 

- 1. Status of NYSDEC Permit for work within the wetland and adjacent areas (including expanded work areas) should be provided.
- 2. Topographic survey depicting modified grading on the site should be provided if additional land excavating/filling occurred outside of previously approved areas.
- 3. Applicant is requested to provide additional information for area depicted on Sheet 3 of 4 above erosion and sediment control notes stating "See Barn Area this sheet". This information is not provided.
- 4. Plan Sheet 2 of 4 at Station 8 + 30 identifies triple 36 inch hdpe, while the plan identifies proposed 30 inch diameter hdpe single pipe. This should be further clarified.
- 5. Status of the large arch culverts should be provided. Design details for culverts are stated by others. This should be submitted to the Building Department for review.
- 6. Erosion and sediment controls should be provided at the perimeter down gradient of all disturbed areas.

Respectfully submitted,

McGoey, Hauser and Edsall Consulting Engineers, P.C.

Patrick J. Hines, Associate