



McGOEY, HAUSER and EDSALL  
CONSULTING ENGINEERS P.C.

**RICHARD D. McGOEY, P.E.** (NY & PA)  
**WILLIAM J. HAUSER, P.E.** (NY, NJ & PA)  
**MARK J. EDSALL, P.E.** (NY, NJ & PA)  
**JAMES M. FARR, P.E.** (NY & PA)

**MAIN OFFICE**  
33 Airport Center Drive  
Suite 202  
New Windsor, New York 12553

**(845) 567-3100**  
**fax: (845) 567-3232**  
**e-mail: mheny@mhepc.com**

**TOWN OF NEWBURGH  
PLANNING BOARD  
REVIEW COMMENTS**

<b>PROJECT:</b>	<b>U-HAUL</b>
<b>PROJECT NO.:</b>	<b>00-59</b>
<b>PROJECT LOCATION:</b>	<b>SECTION 9, BLOCK 3 , LOT 32 AND 66</b>
<b>PROJECT REPRESENTATIVE:</b>	<b>VALDINA ENGINEERING</b>
<b>REVIEW DATE:</b>	<b>18 OCTOBER 2012</b>
<b>MEETING DATE:</b>	<b>18 OCTOBER 2012</b>

1. The size of the proposed propane tank should be clearly labeled on the plans. The Planning Board may want to request a detail of the propane tank, concrete pad, tank fill, etc.
2. Jerry Canfield's comments regarding access through the access control gate system for emergency services should be received. How will gates be operated?

Respectfully submitted,

***McGoey, Hauser and Edsall  
Consulting Engineers, P.C.***

---

Patrick J. Hines, Associate

**REGIONAL OFFICES**

- 111 Wheatfield Drive • Milford, Pennsylvania 18337 • 570-296-2765 •
- 540 Broadway • Monticello, New York 12701 • 845-794-3399 •